



Legislation Details

File #: 34170 **Version:** 1 **Name:** 633 W. Wilson Street
Type: Miscellaneous **Status:** Approved
File created: 5/14/2014 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 5/20/2014
Enactment date: **Enactment #:**
Title: 633 W. Wilson Street (C-05-32-2014)
Potter Lawson, Inc. appealing IBC 705.8, Openings. The rule limits openings on a property line. The Variance requested is to allow an existing concrete structure to be in a new no-build easement. The Fire Department recommends approval as both buildings are sprinkled and the structure is non-combustible.
Sponsors:
Indexes:
Code sections:
Attachments: 1. 633 W Wilson St.pdf

Date	Ver.	Action By	Action	Result
5/20/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass