



## Legislation Details

---

**File #:** 34170      **Version:** 1      **Name:** 633 W. Wilson Street  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 5/14/2014      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 5/20/2014  
**Enactment date:**      **Enactment #:**  
**Title:** 633 W. Wilson Street (C-05-32-2014)  
Potter Lawson, Inc. appealing IBC 705.8, Openings. The rule limits openings on a property line. The Variance requested is to allow an existing concrete structure to be in a new no-build easement. The Fire Department recommends approval as both buildings are sprinkled and the structure is non-combustible.  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 633 W Wilson St.pdf

Date	Ver.	Action By	Action	Result
5/20/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass