



Legislation Details

File #: 64674 **Version:** 1 **Name:** 502 W Washington Ave
Type: Miscellaneous **Status:** Approved
File created: 3/12/2021 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 3/16/2021
Enactment date: **Enactment #:**
Title: 502 W Washington Ave
The property owner is seeking a variance from 2015 IBC 1006.2.1 requiring a second means of egress for group R-2 occupancies with dwelling units having a combined occupant load exceeding 10 individuals but not more than 20 individuals. Alder District 4
Sponsors:
Indexes:
Code sections:
Attachments: 1. 502 W Washington Variance App & Fire Statement.pdf, 2. 502 W Washington Variance Floor Plans.pdf

Date	Ver.	Action By	Action	Result
3/16/2021	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass