



Legislation Details

File #: 44083 **Version:** 1 **Name:** 3425 Hargrove St
Type: Miscellaneous **Status:** Approved
File created: 8/11/2016 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 8/16/2016
Enactment date: **Enactment #:**
Title: 3425 Hargrove St (M-08-56-2016)

Ed Wimmer (builder) appealing SPS 321.08. The rule requires a fire rating when a detached building is less than 10 feet away. They want to use a non rated door.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 3425 Hargrove St.pdf

Date	Ver.	Action By	Action	Result
8/16/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	