



Legislation Details

File #: 33481 **Version:** 1 **Name:** 540 State Street
Type: Miscellaneous **Status:** Approved
File created: 3/19/2014 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 3/25/2014
Enactment date: **Enactment #:**
Title: 540 State Street (C-03-14-2014)
IEBC 912.2 requires sprinklers for this change of use in the second floor. The existing water service is 1 1/2" - 2" and is inadequate to sprinkle the second level. It will cost \$55,000 to put in a 4" main. The proposal is to sprinkle the dining areas and both stairwells. The Fire Department requires the system be monitored and a new 4" main be provided within 8 years.

Sponsors:
Indexes:
Code sections:
Attachments: 1. 540 State Street.pdf

Date	Ver.	Action By	Action	Result
3/25/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass