



## Legislation Details

---

**File #:** 33481      **Version:** 1      **Name:** 540 State Street  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 3/19/2014      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 3/25/2014  
**Enactment date:**      **Enactment #:**  
**Title:** 540 State Street (C-03-14-2014)  
IEBC 912.2 requires sprinklers for this change of use in the second floor. The existing water service is 1 1/2" - 2" and is inadequate to sprinkle the second level. It will cost \$55,000 to put in a 4" main. The proposal is to sprinkle the dining areas and both stairwells. The Fire Department requires the system be monitored and a new 4" main be provided within 8 years.

**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 540 State Street.pdf

Date	Ver.	Action By	Action	Result
3/25/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass