



# City of Madison

City of Madison  
Madison, WI 53703  
www.cityofmadison.com

## Legislation Text

---

**File #:** 45476, **Version:** 1

---

### **Title**

560 North St (C-12-76-2016)

William Tracy appealing IBC 1208.2. The rule requires clearance at obstructions to be 7' 6". The variance requested is to allow existing clearance of 6' 7". The Madison Fire Department differed to the board. 12th Ald. Dist.