



## Legislation Details

---

**File #:** 66370      **Version:** 1      **Name:**  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 7/8/2021      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 8/11/2021  
**Enactment date:**      **Enactment #:**

**Title:** 30 Ash St  
BLDVAR-2021-10505  
Seeking a variance from 2015 IBC Table 504.4 limiting Type IIIB Group E buildings with sprinkler systems to a maximum of 3 stories above grade. The property owner is proposing an addition to extend elevator service to an existing fourth story above grade. Alder District 5.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. MMSD 5 - 30 Ash height.pdf, 2. Ash St 30 IBC 504 MFD Position 7-2-2021.pdf

Date	Ver.	Action By	Action	Result
8/11/2021	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass