



## Legislation Text

---

**File #:** 34170, **Version:** 1

---

### **Title**

633 W. Wilson Street (C-05-32-2014)

Potter Lawson, Inc. appealing IBC 705.8, Openings. The rule limits openings on a property line. The Variance requested is to allow an existing concrete structure to be in a new no-build easement. The Fire Department recommends approval as both buildings are sprinkled and the structure is non-combustible.