



Legislation Details

File #: 40456 **Version:** 1 **Name:** 109 E. Lakeside Street
Type: Miscellaneous **Status:** Approved
File created: 10/14/2015 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 10/20/2015
Enactment date: **Enactment #:**
Title: 109 E. Lakeside Street (C-10-50-2015)

Charlie Ethridge of Glueck Architects appeals IBC 705.8. The rule requires that from 0 to 3 feet openings are not permitted. This is an existing building that is undergoing a change of use. There is a permanent utility easement along the wall in question so it cannot be built upon. The Madison Fire Department supports the variance.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 20151014144641060.pdf

Date	Ver.	Action By	Action	Result
10/20/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	