



## Legislation Details

---

**File #:** 54643      **Version:** 1      **Name:** 4101 Lien Rd  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 2/7/2019      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 2/20/2019  
**Enactment date:**      **Enactment #:**

**Title:** 4101 Lien Rd.  
BLDNCC-2018-14504  
Roger Schregardus of Boldt Technical Services is seeking a variance to allow a 12" landing instead of the 44" landing as required under IBC 1010.1.6. The doors in question are Fire Department Access doors to high-piled storage per IFC 3206.6.1. The Fire Department Supports the variance.  
Alder District 17

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 4101 Lien Rd Petition for Variance Application.pdf

Date	Ver.	Action By	Action	Result
2/20/2019	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	