



Legislation Details

File #: 47655 **Version:** 1 **Name:** 2713 Atwood Ave
Type: Miscellaneous **Status:** Approved
File created: 6/12/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 6/20/2017
Enactment date: **Enactment #:**
Title: 2713 Atwood Ave (C-06-50-2017)
Paul Reed of Harmony Construction Management Inc appealing IBC 1008.1.5.
The rule requires a landing at the door. The variance requested is to allow a six inch step at the patio door without a landing.
Sponsors:
Indexes:
Code sections:
Attachments: 1. 2713 Atwood Ave application.pdf, 2. 2713 Atwood Ave plans.pdf

Date	Ver.	Action By	Action	Result
6/20/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	