



## Legislation Details

---

**File #:** 50541      **Version:** 1      **Name:** 9901 Silicon Prairie Parkway  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 2/14/2018      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 2/21/2018  
**Enactment date:**      **Enactment #:**  
**Title:** 9901 Silicon Prairie Parkway (M-2-13-2018)  
Preston Tokheim, Newcomb Construction Co, appealing MGO 34.604 Emergency and Standby Power Systems. The rule does not allow natural gas to be used as a standby fuel source for the network room. Additional safety is being provided by a separate line.  
Alder District 9

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. Silicon Prairie Pkwy 9901 M-02-13-2018.pdf

Date	Ver.	Action By	Action	Result
2/21/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	