



Legislation Details

File #: 47296 **Version:** 1 **Name:** 432 W GORHAM ST
Type: Miscellaneous **Status:** Approved
File created: 5/11/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 5/16/2017
Enactment date: **Enactment #:**

Title: 432 W Gorham St (C-05-29-2017)
Antunovich Associates appealing IBC 3007.4.4. The rule requires that the Fire Service Access Elevator Lobby be a minimum of 150 sq. ft. in area with a minimum dimension of 8'. The variance requested is to allow a lobby of 184 sq. ft. with dimensions of 7'2" x 25'9". The Madison Fire Department recommends approval. Aldermanic District 4

Sponsors:

Indexes:

Code sections:

Attachments: 1. 432 W GORHAM ST.pdf

Date	Ver.	Action By	Action	Result
5/16/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	