



## Legislation Details

---

**File #:** 44081      **Version:** 1      **Name:** 506 State St  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 8/11/2016      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 9/1/2016  
**Enactment date:**      **Enactment #:**  
**Title:** 506 State St (C-08-54-2016)

Agent: L2M Inc, appealing IBC 2009 1009.2 headroom, 1009.4.2 stair risers, and 1009.4.2 minimum stair treads. The variance requested is to allow 5' 10" headroom, 8 inch risers, and 10 inch treads for an existing condition.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 506 State St.pdf

Date	Ver.	Action By	Action	Result
9/1/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	
8/16/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Table	