



Legislation Details (With Text)

File #: 24041 **Version:** 1 **Name:** Exception
Type: Ordinance **Status:** Passed
File created: 9/27/2011 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: 11/1/2011 **Final action:** 11/1/2011
Enactment date: 11/9/2011 **Enactment #:** ORD-11-00152
Title: Amending Section 34.507(1)(b) of the Madison General Ordinances to exempt private fire service mains from Madison Fire Department (MFD) plan review.
Sponsors: Shiva Bidar, Tim Bruer, Lauren Cnare, Satya V. Rhodes-Conway, Paul E. Skidmore
Indexes:
Code sections:
Attachments:

Date	Ver.	Action By	Action	Result
11/1/2011	1	COMMON COUNCIL	Adopt with the Recommendation(s)	Pass
10/18/2011	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	RECOMMEND TO COUNCIL TO ADOPT WITH THE FOLLOWING RECOMMENDATIONS - REPORT OF OFFICER	Pass
10/4/2011	1	COMMON COUNCIL	Referred	
9/27/2011	1	Attorney's Office/Approval Group	Referred for Introduction	

Fiscal Note

No appropriation is required.

Title

Amending Section 34.507(1)(b) of the Madison General Ordinances to exempt private fire service mains from Madison Fire Department (MFD) plan review.

Body

DRAFTER'S ANALYSIS: This ordinance creates an exception from MFD plan review for private fire service mains that do not supply a fire hydrant. As long as the plans for these mains have been reviewed and approved by the Building Inspection Division, the plans do not need to be reviewed by MFD.

The Common Council of the City of Madison do hereby ordain as follows:

Subdivision (b) of Subsection (1) entitled "Fire Protection Water Supply and Fire Hydrants" of Section 34.507 entitled "Fire Protection Water Supply" of the Madison General Ordinances is amended to read as follows:

"(b) Plans shall be submitted to the Chief for review to determine compliance with the applicable standards prior to the installation of private fire service mains and fire hydrants. The Chief shall act upon such applications within fifteen (15) days of receipt. Denials of such applications may be appealed to the Board. Exception: Plans for private fire service mains that do not supply a fire hydrant do not have to be submitted under this subdivision, if said plans for private fire service mains have been submitted, approved, and inspected by the City of Madison Building Inspection Division."