



Legislation Details (With Text)

File #: 26713 **Version:** 1 **Name:** 345 W. Washington Avenue, Ste 202
Type: Miscellaneous **Status:** Approved
File created: 6/12/2012 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 6/19/2012
Enactment date: **Enactment #:**
Title: 345 W. Washington Avenue, Suite 202 (C-06-26-2012)
Alexander Company appealing IBC 403.5.3. The rule requires that the stairway doors shall be capable of being unlocked upon a signal from the Fire Department. Drug Enforcement Agency requires 100% secure space at all times. The Variance requested is to allow a key to be placed in a knox box for use by the Fire Department for Stair 202.
Sponsors:
Indexes:
Code sections:
Attachments: 1. 345 W Washington Ave Ste 202.pdf

Date	Ver.	Action By	Action	Result
6/19/2012	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

Title
345 W. Washington Avenue, Suite 202 (C-06-26-2012)
Alexander Company appealing IBC 403.5.3. The rule requires that the stairway doors shall be capable of being unlocked upon a signal from the Fire Department. Drug Enforcement Agency requires 100% secure space at all times. The Variance requested is to allow a key to be placed in a knox box for use by the Fire Department for Stair 202.