



## Legislation Details

---

**File #:** 33755      **Version:** 1      **Name:** 2039 Winnebago Street\_Basement

**Type:** Miscellaneous      **Status:** Approved

**File created:** 4/15/2014      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

**On agenda:**      **Final action:** 4/22/2014

**Enactment date:**      **Enactment #:**

**Title:** 2039 Winnebago Street (C-04-21-2014)  
Mark Schmidt, Architect, appealing IBC 1208.2. The rule requires that the minimum ceiling height in a commercial space be 7' 6". The Variance requested is to allow 7' 0" in an existing building. The Madison Fire Department has no comment.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 2039 Winnebago St\_Basement.pdf

Date	Ver.	Action By	Action	Result
4/22/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass