



Legislation Details (With Text)

File #: 34810 **Version:** 1 **Name:** 1949 E. Main Street
Type: Miscellaneous **Status:** Approved
File created: 7/9/2014 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 7/15/2014
Enactment date: **Enactment #:**

Title: 1949 E. Main Street (M-07-42-2014)
Patricia Brown appealing SPS 321.08. The rule requires walls within 3 feet of a property line be 3/4 hour walls with 20 minute doors and windows. The Variance requested is to allow a second floor porch addition conforming to the existing setback of the building. The owner is offering to drywall the outside.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 1949 E Main St.pdf

Date	Ver.	Action By	Action	Result
7/15/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

Title

1949 E. Main Street (M-07-42-2014)
Patricia Brown appealing SPS 321.08. The rule requires walls within 3 feet of a property line be 3/4 hour walls with 20 minute doors and windows. The Variance requested is to allow a second floor porch addition conforming to the existing setback of the building. The owner is offering to drywall the outside.