



## Legislation Details

---

**File #:** 34810      **Version:** 1      **Name:** 1949 E. Main Street  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 7/9/2014      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 7/15/2014  
**Enactment date:**      **Enactment #:**  
**Title:** 1949 E. Main Street (M-07-42-2014)  
Patricia Brown appealing SPS 321.08. The rule requires walls within 3 feet of a property line be 3/4 hour walls with 20 minute doors and windows. The Variance requested is to allow a second floor porch addition conforming to the existing setback of the building. The owner is offering to drywall the outside.  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 1949 E Main St.pdf

Date	Ver.	Action By	Action	Result
7/15/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass