



Legislation Details (With Text)

File #: 36882 **Version:** 1 **Name:** 316 W. Washington Avenue
Type: Miscellaneous **Status:** Approved
File created: 1/15/2015 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 1/20/2015
Enactment date: **Enactment #:**

Title: 316 W. Washington Avenue (C-01-01-15)
Ray White of Dimension IV Madison, LLC appealing IBC 1023.5. The rule does not allow elevators to open into an exit passageway. The Variance is to allow an additional elevator shaft door in Stair 8. The Madison Fire Department supports the Variance with the additional means of safety provided.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 316 W Washington Ave.pdf

Date	Ver.	Action By	Action	Result
1/20/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

Title

316 W. Washington Avenue (C-01-01-15)
Ray White of Dimension IV Madison, LLC appealing IBC 1023.5. The rule does not allow elevators to open into an exit passageway. The Variance is to allow an additional elevator shaft door in Stair 8. The Madison Fire Department supports the Variance with the additional means of safety provided.