



## Legislation Details

---

**File #:** 36883      **Version:** 1      **Name:** 800 N. Block East Washington Avenue  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 1/15/2015      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 1/20/2015  
**Enactment date:**      **Enactment #:**  
**Title:** 800 N. Block East Washington Avenue (M-01-02-2015)  
Chris Gosch of Bark Design appealing IBC 602.2. The rule requires that Type 1 and Type 2 Construction have non-combustible elements as listed in Table 601. The Variance requested is to use 12 heavy timber columns in the low rise grocery store. The Madison Fire Department supports the Variance.  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 800 N Block East Washington Ave.pdf, 2. WholeTrees Attachment 1-20-15.pdf

Date	Ver.	Action By	Action	Result
1/20/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass