



## Legislation Details

---

**File #:** 38043      **Version:** 1      **Name:** 673 State Street  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 4/15/2015      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 4/21/2015  
**Enactment date:**      **Enactment #:**  
**Title:** 673 State Street (C-04-20-2015)  
Glueck Architects appealing IBC 1010.6.1. The rule requires that landings not slope more than 2%.  
The Variance requested is to allow an existing slope of five inches in four feet.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 673 State St.pdf

Date	Ver.	Action By	Action	Result
4/21/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass