



Legislation Details (With Text)

File #:	40067	Version:	1	Name:	3402 Kinsman Boulevard
Type:	Miscellaneous	Status:		Status:	Approved
File created:	9/8/2015	In control:		In control:	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda:		Final action:		Final action:	9/16/2015
Enactment date:		Enactment #:		Enactment #:	
Title:	3402 Kinsman Boulevard (C-09-43-2015)				

Cliff Goodhart of Eppstein Uhen Architects appeals IBC 1008.1.4.4. The variance requested is to allow egress doors to be opened in a sequence so that two doors are not open at the same time. The Madison Fire Department supports the variance with conditions.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 3402 Kinsman Boulevard.pdf

Date	Ver.	Action By	Action	Result
9/16/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

3402 Kinsman Boulevard (C-09-43-2015)

Cliff Goodhart of Eppstein Uhen Architects appeals IBC 1008.1.4.4. The variance requested is to allow egress doors to be opened in a sequence so that two doors are not open at the same time. The Madison Fire Department supports the variance with conditions.