



## Legislation Details

---

|                        |                                       |                      |   |                      |  |
|------------------------|---------------------------------------|----------------------|---|----------------------|--|
| <b>File #:</b>         | 40067                                 | <b>Version:</b>      | 1 | <b>Name:</b>         | 3402 Kinsman Boulevard   |
| <b>Type:</b>           | Miscellaneous                         | <b>Status:</b>       |   | <b>Status:</b>       | Approved   |
| <b>File created:</b>   | 9/8/2015                              | <b>In control:</b>   |   | <b>In control:</b>   | BUILDING CODE, FIRE CODE, CONVEYANCE<br>CODE AND LICENSING APPEALS BOARD |
| <b>On agenda:</b>      |                                       | <b>Final action:</b> |   | <b>Final action:</b> | 9/16/2015  |
| <b>Enactment date:</b> |                                       | <b>Enactment #:</b>  |   | <b>Enactment #:</b>  |  |
| <b>Title:</b>          | 3402 Kinsman Boulevard (C-09-43-2015) |                      |   |                      |  |

Cliff Goodhart of Eppstein Uhen Architects appeals IBC 1008.1.4.4. The variance requested is to allow egress doors to be opened in a sequence so that two doors are not open at the same time. The Madison Fire Department supports the variance with conditions.

**Sponsors:****Indexes:****Code sections:****Attachments:** 1. 3402 Kinsman Boulevard.pdf

| Date      | Ver. | Action By   | Action  | Result |
|-----------|------|---|---------|--------|
| 9/16/2015 | 1    | BUILDING CODE, FIRE CODE,<br>CONVEYANCE CODE AND<br>LICENSING APPEALS BOARD | Approve |        |