



Legislation Details

File #:	40456	Version:	1	Name:	109 E. Lakeside Street
Type:	Miscellaneous	Status:		Status:	Approved
File created:	10/14/2015	In control:		In control:	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda:		Final action:		Final action:	10/20/2015
Enactment date:		Enactment #:		Enactment #:	
Title:	109 E. Lakeside Street (C-10-50-2015)				

Charlie Ethridge of Glueck Architects appeals IBC 705.8. The rule requires that from 0 to 3 feet openings are not permitted. This is an existing building that is undergoing a change of use. There is a permanent utility easement along the wall in question so it cannot be built upon. The Madison Fire Department supports the variance.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 20151014144641060.pdf

Date	Ver.	Action By	Action	Result
10/20/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	