



## Legislation Details

---

**File #:** 41759      **Version:** 1      **Name:** 680 Grand Canyon Drive Suite #5  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 2/10/2016      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 2/23/2016  
**Enactment date:**      **Enactment #:**  
**Title:** 680 Grand Canyon Drive Suite #5 (C-02-08-2016)  
Dan Schmidt of Beltline LLC appealing IBC Section 1010.2. The rule requires that non egress ramps have a slope of less than 1:8. The variance requested is to allow a convenience ramp of 1:6.44. Additional means of safety is being provided with an additional exit from the lower level and additional smoke detector stations.  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 680 Grand Canyon Drive Suite #5.pdf

Date	Ver.	Action By	Action	Result
2/23/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	