



Legislation Details (With Text)

**File #:** 41765      **Version:** 1      **Name:** 636 State Street  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 2/10/2016      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 2/23/2016  
**Enactment date:**      **Enactment #:**

**Title:** 636 State Street (C-02-09-2016)  
 Jenny Dechant of Iconica appealing IBC 705.8.1. The rule does not allow openings on a property line. The variance requested is to allow an existing stairway at 610 State Street to lead to the basement at 638 State Street. A new two hour enclosure would be constructed. The Madison Fire Department supports the variance with conditions.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 636 State Street.pdf

Date	Ver.	Action By	Action	Result
2/23/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

**Title**

636 State Street (C-02-09-2016)  
 Jenny Dechant of Iconica appealing IBC 705.8.1. The rule does not allow openings on a property line. The variance requested is to allow an existing stairway at 610 State Street to lead to the basement at 638 State Street. A new two hour enclosure would be constructed. The Madison Fire Department supports the variance with conditions.