



## Legislation Details

---

**File #:** 43738      **Version:** 1      **Name:** 9614 Red Forest Lane  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 7/13/2016      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE  
CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 7/19/2016  
**Enactment date:**      **Enactment #:**  
**Title:** 9614 Red Forest Lane (M-07-45-2016)

TR McKenzie appealing IBC 3004.1, 2009. The rule requires that hoistway venting be required for shafts of 3 or more stories. The variance requested is to use the 2015 IBC that does not require the venting. The Madison Fire Department supports the variance.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 9614 Red Forest Lane.pdf

Date	Ver.	Action By	Action	Result
7/19/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	