



## Legislation Details

---

**File #:** 43740      **Version:** 1      **Name:** 9619 Ancient Oak Lane  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 7/13/2016      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 7/19/2016  
**Enactment date:**      **Enactment #:**  
**Title:** 9619 Ancient Oak Lane (C-07-46-2016)  
TR McKenzie Inc appealing IBC 3004.1, 2009. The rule requires that hoistway venting be required for shafts of 3 or more stories. The variance requested is to use the 2015 IBC that does not require the venting. The Madison Fire Department supports the variance.  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 9619 Ancient Oak Lane.pdf

| Date      | Ver. | Action By   | Action  | Result |
|-----------|------|---|---------|--------|
| 7/19/2016 | 1    | BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD | Approve |        |