



Legislation Details (With Text)

File #:	43742	Version:	1	Name:	315 S Patterson St
Type:	Miscellaneous	Status:		Status:	Approved
File created:	7/13/2016	In control:		In control:	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda:		Final action:		Final action:	7/19/2016
Enactment date:		Enactment #:			
Title:	315 S Patterson St (C-07-47-2016)				

Harker Heating appealing IBC 3004.1, 2009. The rule requires that hoistway venting be required for shafts of 3 or more stories. The variance requested is to use the 2015 IBC that does not require the venting. The Madison Fire Department supports the variance.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 315 S Patterson St.pdf

Date	Ver.	Action By	Action	Result
7/19/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

315 S Patterson St (C-07-47-2016)

Harker Heating appealing IBC 3004.1, 2009. The rule requires that hoistway venting be required for shafts of 3 or more stories. The variance requested is to use the 2015 IBC that does not require the venting. The Madison Fire Department supports the variance.