



## Legislation Details (With Text)

---

<b>File #:</b>	43750	<b>Version:</b>	1	<b>Name:</b>	739 Williamson St
<b>Type:</b>	Miscellaneous	<b>Status:</b>	Approved		
<b>File created:</b>	7/13/2016	<b>In control:</b>	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD		
<b>On agenda:</b>		<b>Final action:</b>	7/19/2016		
<b>Enactment date:</b>		<b>Enactment #:</b>			
<b>Title:</b>	739 Williamson St (C-07-48-2016)				

TJK Design appealing IBC 3004.1, 2009. The rule requires that hoistway venting be required for shafts of 3 or more stories. The variance requested is to use the 2015 IBC that does not require the venting. The Madison Fire Department supports the variance.

### Sponsors:

### Indexes:

### Code sections:

**Attachments:** 1. 739 Williamson St.pdf

Date	Ver.	Action By	Action	Result
7/19/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

### Title

739 Williamson St (C-07-48-2016)

TJK Design appealing IBC 3004.1, 2009. The rule requires that hoistway venting be required for shafts of 3 or more stories. The variance requested is to use the 2015 IBC that does not require the venting. The Madison Fire Department supports the variance.