



Legislation Details

File #: 44491 **Version:** 1 **Name:** 3418 S STONE CREEK CIR
Type: Miscellaneous **Status:** Approved
File created: 9/16/2016 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 9/20/2016
Enactment date: **Enactment #:**
Title: 3418 S Stone Creek Cir (C-09-59-2016)
Bouril Design appealing IBC 1208.2.1. The ruling requires the furred ceiling high to be 7'0". In addition the minimum door height shall be 80". The variance requested is to have a ceiling height in the basement of 6'7" and door heights of 76.5". The Madison Fire Department supports the variance with an extended smoke alarm system and a sprinkler system.
Sponsors:
Indexes:
Code sections:
Attachments: 1. 3418 S STONE CREEK CIR.pdf

Date	Ver.	Action By	Action	Result
9/20/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	