



Legislation Details (With Text)

File #: 46071 **Version:** 1 **Name:** 4802 FEMRITE DR
Type: Miscellaneous **Status:** Approved
File created: 2/8/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/22/2017
Enactment date: **Enactment #:**
Title: 4802 Femrite Dr (C-02-05-2017)
JSD Inc appealing IBC 1008.1.7. Threshold shall be less than 3/4 of an inch. The variance requested is to have a threshold of six inches in a cooler addition. The Madison Fire Department supports the varince with a contrasting color on the threshold. 16th Ald. Dist.

Sponsors:
Indexes:
Code sections:
Attachments: 1. 4802 FEMRITE DR.pdf

Date	Ver.	Action By	Action	Result
2/22/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

4802 Femrite Dr (C-02-05-2017)
JSD Inc appealing IBC 1008.1.7. Threshold shall be less than 3/4 of an inch. The variance requested is to have a threshold of six inches in a cooler addition. The Madison Fire Department supports the varince with a contrasting color on the threshold. 16th Ald. Dist.