



## Legislation Details

---

**File #:** 46071      **Version:** 1      **Name:** 4802 FEMRITE DR  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 2/8/2017      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 2/22/2017  
**Enactment date:**      **Enactment #:**  
**Title:** 4802 Femrite Dr (C-02-05-2017)  
JSD Inc appealing IBC 1008.1.7. Threshold shall be less than 3/4 of an inch. The variance requested is to have a threshold of six inches in a cooler addition. The Madison Fire Department supports the variance with a contrasting color on the threshold. 16th Ald. Dist.  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 4802 FEMRITE DR.pdf

Date	Ver.	Action By	Action	Result
2/22/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	