



Legislation Details

File #: 46566 **Version:** 1 **Name:** 1021 University Ave
Type: Miscellaneous **Status:** Approved
File created: 3/16/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 3/21/2017
Enactment date: **Enactment #:**
Title: 1021 University Ave (C-03-11-2017)
Vince Micha of The Kubala Washatko Arch Inc appealing IBC 1023.5 openings and penetrations. The proposed openings via fire shutters 122b and 122c into the horizontal exit stair. Additional means of safety is being provided by adding sprinklers in the East Education Wing. The Madison Fire Department approves the variance with the addition of sprinklers. 8th Ald. Dist.

Sponsors:
Indexes:
Code sections:
Attachments: 1. 1021 University Ave.pdf

Date	Ver.	Action By	Action	Result
3/21/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	