



## Legislation Details

---

**File #:** 47655      **Version:** 1      **Name:** 2713 Atwood Ave  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 6/12/2017      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 6/20/2017  
**Enactment date:**      **Enactment #:**  
**Title:** 2713 Atwood Ave (C-06-50-2017)  
Paul Reed of Harmony Construction Management Inc appealing IBC 1008.1.5.  
The rule requires a landing at the door. The variance requested is to allow a six inch step at the patio door without a landing.  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 2713 Atwood Ave application.pdf, 2. 2713 Atwood Ave plans.pdf

Date	Ver.	Action By	Action	Result
6/20/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	