



Legislation Details (With Text)

File #: 47656 **Version:** 1 **Name:** 903 Delaplaine Ct
Type: Miscellaneous **Status:** Approved
File created: 6/12/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 6/20/2017
Enactment date: **Enactment #:**
Title: 903 Delaplaine Ct (M-06-51-2017)
Knothe & Bruce Architects LLC appealing MGO 34.604.
The ordinance requires an on-site fuel source for Emergency Standby Power Systems. The variance requested is to use the natural gas pipeline. The Madison Fire Department supports the variance with a separate connection.

Sponsors:
Indexes:
Code sections:
Attachments: 1. 903 Delaplaine Ct.pdf

Date	Ver.	Action By	Action	Result
6/20/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

903 Delaplaine Ct (M-06-51-2017)
Knothe & Bruce Architects LLC appealing MGO 34.604.
The ordinance requires an on-site fuel source for Emergency Standby Power Systems. The variance requested is to use the natural gas pipeline. The Madison Fire Department supports the variance with a separate connection.