



Legislation Details (With Text)

File #: 49146 **Version:** 1 **Name:** 2221 Mustang Way (C-10-75-2017)
Chris Kilen of Kilen Engineering appealing IBC 503.1 and IBC 903.2.4. The rule requires automatic sprinklers because the addition exceeds the area limits. The variance is requested because a fire wall would restrict move me

Type: Miscellaneous **Status:** Approved

File created: 10/9/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

On agenda: **Final action:** 10/17/2017

Enactment date: **Enactment #:**

Title: 2221 Mustang Way (C-10-75-2017)
Chris Kilen of Kilen Engineering appealing IBC 503.1 and IBC 903.2.4. The rule requires automatic sprinklers because the addition exceeds the area limits. The variance is requested because a fire wall would restrict movement. The proposal is to sprinkle entire building over the next ten years. The Madison Fire Department supports the variance as long as all high-piled and Group A plastics storage is sprinkled. The balance of the building shall be sprinkled by 12-31-2024.
Alder District 16

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2221 Mustang Way.pdf

Date	Ver.	Action By	Action	Result
10/17/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

2221 Mustang Way (C-10-75-2017)

Chris Kilen of Kilen Engineering appealing IBC 503.1 and IBC 903.2.4. The rule requires automatic sprinklers because the addition exceeds the area limits. The variance is requested because a fire wall would restrict movement. The proposal is to sprinkle entire building over the next ten years. The Madison Fire Department supports the variance as long as all high-piled and Group A plastics storage is sprinkled. The balance of the building shall be sprinkled by 12-31-2024.
Alder District 16