



Legislation Details

File #:	49146	Version:	1	Name:	2221 Mustang Way (C-10-75-2017) Chris Kilen of Kilen Engineering appealing IBC 503.1 and IBC 903.2.4. The rule requires automatic sprinklers because the addition exceeds the area limits. The variance is requested because a fire wall would restrict move
Type:	Miscellaneous	Status:			Approved
File created:	10/9/2017	In control:			BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda:		Final action:			10/17/2017
Enactment date:		Enactment #:			
Title:	2221 Mustang Way (C-10-75-2017) Chris Kilen of Kilen Engineering appealing IBC 503.1 and IBC 903.2.4. The rule requires automatic sprinklers because the addition exceeds the area limits. The variance is requested because a fire wall would restrict movement. The proposal is to sprinkle entire building over the next ten years. The Madison Fire Department supports the variance as long as all high-piled and Group A plastics storage is sprinkled. The balance of the building shall be sprinkled by 12-31-2024. Alder District 16				
Sponsors:					
Indexes:					
Code sections:					
Attachments:	1. 2221 Mustang Way.pdf				

Date	Ver.	Action By	Action	Result
10/17/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	