



## Legislation Details (With Text)

---

**File #:** 49842      **Version:** 1      **Name:** 111 S Livingston Ave  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 12/13/2017      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 12/19/2017  
**Enactment date:**      **Enactment #:**

**Title:** 111 S Livingston St M-12-87-2017  
Dan Windorski of GRAEF appealing MGO 34.503. The rule, thru the adoption of the IFC 2015, requires a street to be 26 feet wide. The variance requested is to allow an existing street of 22 feet wide. The Madison Fire Department supports the variance. Alder District 6

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. Livingston St 111 S application.pdf

Date	Ver.	Action By	Action	Result
12/19/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

**Title**

111 S Livingston St M-12-87-2017  
Dan Windorski of GRAEF appealing MGO 34.503. The rule, thru the adoption of the IFC 2015, requires a street to be 26 feet wide. The variance requested is to allow an existing street of 22 feet wide. The Madison Fire Department supports the variance. Alder District 6