



Legislation Details (With Text)

File #: 49844 **Version:** 1 **Name:** 1929 Winnebago St
Type: Miscellaneous **Status:** Approved
File created: 12/13/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/21/2018
Enactment date: **Enactment #:**
Title: 1929 Winnebago St (C-12-89-2017)
Jacob Morrison of AIA appealing IBC 2009 - 1009.4.2. The code requires a new stairway have risers less than 7 inches and treads of 11 inches. The variance requested is to build a new stairway in the existing space with 7.5 inch risers and treads of 9.25 inches.
Alder District 6
Sponsors:
Indexes:
Code sections:
Attachments: 1. Winnebago St 1929 C-12-89-2017.pdf, 2. Winnebago St 1929 12-89-2017 Revised.pdf

Date	Ver.	Action By	Action	Result
2/21/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	
12/19/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Table	

Title

1929 Winnebago St (C-12-89-2017)
Jacob Morrison of AIA appealing IBC 2009 - 1009.4.2. The code requires a new stairway have risers less than 7 inches and treads of 11 inches. The variance requested is to build a new stairway in the existing space with 7.5 inch risers and treads of 9.25 inches.
Alder District 6