



Legislation Details (With Text)

File #: 50541 **Version:** 1 **Name:** 9901 Silicon Prairie Parkway
Type: Miscellaneous **Status:** Approved
File created: 2/14/2018 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/21/2018
Enactment date: **Enactment #:**
Title: 9901 Silicon Prairie Parkway (M-2-13-2018)
Preston Tokheim, Newcomb Construction Co, appealing MGO 34.604 Emergency and Standby Power Systems. The rule does not allow natural gas to be used as a standby fuel source for the network room. Additional safety is being provided by a separate line.
Alder District 9
Sponsors:
Indexes:
Code sections:
Attachments: 1. Silicon Prairie Pkwy 9901 M-02-13-2018.pdf

Date	Ver.	Action By	Action	Result
2/21/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

9901 Silicon Prairie Parkway (M-2-13-2018)
Preston Tokheim, Newcomb Construction Co, appealing MGO 34.604 Emergency and Standby Power Systems. The rule does not allow natural gas to be used as a standby fuel source for the network room. Additional safety is being provided by a separate line.
Alder District 9