



Legislation Details (With Text)

File #: 50911 **Version:** 1 **Name:** 2219 Monroe St
Type: Miscellaneous **Status:** Approved
File created: 3/13/2018 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 3/20/2018
Enactment date: **Enactment #:**
Title: 2219 Monroe St C-3-31-2018
Jim Moravec of Potter Lawson appealing IBC Table 503 of the 2009 IBC. The rule requires that the new elevator addition be separated from the non-sprinklered portion of the building. It is not structurally feasible. The proposal is to sprinkle the planned addition and remodeling of the existing high school. Standpipes will be added to the closed stairwells in the 1925 building. The rest of the complex will be sprinklered by 2033.
Madison Fire Dept. recommendation: Conditional Approval
Alder District 13

Sponsors:
Indexes:
Code sections:
Attachments: 1. 2219 Monroe St application.pdf

Date	Ver.	Action By	Action	Result
3/20/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

2219 Monroe St C-3-31-2018
Jim Moravec of Potter Lawson appealing IBC Table 503 of the 2009 IBC. The rule requires that the new elevator addition be separated from the non-sprinklered portion of the building. It is not structurally feasible. The proposal is to sprinkle the planned addition and remodeling of the existing high school. Standpipes will be added to the closed stairwells in the 1925 building. The rest of the complex will be sprinklered by 2033.
Madison Fire Dept. recommendation: Conditional Approval
Alder District 13