



Legislation Details (With Text)

File #: 50912 **Version:** 1 **Name:** 2537 Daniels St
Type: Miscellaneous **Status:** Approved
File created: 3/13/2018 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 3/20/2018
Enactment date: **Enactment #:**

Title: 2537 Daniels St C-3-32-2018
Kenneth Berg of Specialized Electric appealing MGO 34.604. The rule requires that an on-site fuel supply be provided for the generator. The variance requested is to use a separate gas supply from MGE with separate valve to provide the second source. The Madison Fire Department is in the process of changing this ordinance.
Alder District 16

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2537 Daniels St application.pdf

Date	Ver.	Action By	Action	Result
3/20/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

2537 Daniels St C-3-32-2018

Kenneth Berg of Specialized Electric appealing MGO 34.604. The rule requires that an on-site fuel supply be provided for the generator. The variance requested is to use a separate gas supply from MGE with separate valve to provide the second source. The Madison Fire Department is in the process of changing this ordinance.
Alder District 16