



## Legislation Details

**File #:** 50915      **Version:** 1      **Name:** 803 Williamson St  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 3/13/2018      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 4/17/2018  
**Enactment date:** 4/23/2018      **Enactment #:**  
**Title:** 803 Williamson St C-3-33-2018  
Charlie Ethridge of Glueck Associates appealing IBC 1107.7.1. At least one story containing dwelling units shall be provided with an accessible entrance from the exterior of the structure and all units shall be type B units. The variance requested is to allow a level 4 feet higher without a lift due to site constraints.  
Alder District 6  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 803 Williamson St application.pdf, 2. 803 Williamson St application rev.pdf

Date	Ver.	Action By	Action	Result
4/17/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	
3/20/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Refer	