



Legislation Details (With Text)

File #: 50916 **Version:** 1 **Name:** 501 Charmany Dr
Type: Miscellaneous **Status:** Approved
File created: 3/13/2018 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 3/20/2018
Enactment date: **Enactment #:**

Title: 501 Charmany Dr C-3-34-2018
Robert Webber of Valerio Dewalt Train Associates appealing IBC 2009 Section 1005.1. The rule establishes 0.3" per occupant in the stairways and 0.2" per occupant for other egress components. The variance requested is to use the 2015 International Building Code in lieu of the 2009. The 2015 IBC will be used in its entirety. This project will use the 2009 Energy Conservation Code.
Madison Fire Dept. recommendation: Conditional Approval
Alder District 19

Sponsors:

Indexes:

Code sections:

Attachments: 1. 501 Charmany Dr application.pdf

Date	Ver.	Action By	Action	Result
3/20/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

501 Charmany Dr C-3-34-2018
Robert Webber of Valerio Dewalt Train Associates appealing IBC 2009 Section 1005.1. The rule establishes 0.3" per occupant in the stairways and 0.2" per occupant for other egress components. The variance requested is to use the 2015 International Building Code in lieu of the 2009. The 2015 IBC will be used in its entirety. This project will use the 2009 Energy Conservation Code.
Madison Fire Dept. recommendation: Conditional Approval
Alder District 19