



## Legislation Details

---

<b>File #:</b>	50916	<b>Version:</b>	1	<b>Name:</b>	501 Charmany Dr
<b>Type:</b>	Miscellaneous	<b>Status:</b>		<b>Status:</b>	Approved
<b>File created:</b>	3/13/2018	<b>In control:</b>		<b>In control:</b>	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
<b>On agenda:</b>		<b>Final action:</b>		<b>Final action:</b>	3/20/2018
<b>Enactment date:</b>		<b>Enactment #:</b>			

**Title:** 501 Charmany Dr C-3-34-2018  
Robert Webber of Valerio Dewalt Train Associates appealing IBC 2009 Section 1005.1.  
The rule establishes 0.3" per occupant in the stairways and 0.2" per occupant for other egress  
components. The variance requested is to use the 2015 International Building Code in lieu of the  
2009. The 2015 IBC will be used in its entirety. This project will use the 2009 Energy Conservation  
Code.  
Madison Fire Dept. recommendation: Conditional Approval  
Alder District 19

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 501 Charmany Dr application.pdf

Date	Ver.	Action By	Action	Result
3/20/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	