



Legislation Details (With Text)

File #: 52419 **Version:** 1 **Name:** 215 Martin Luther King Jr Blvd
Type: Miscellaneous **Status:** Approved
File created: 7/11/2018 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 7/17/2018
Enactment date: **Enactment #:**
Title: 215 Martin Luther King Jr Blvd C-07-60-2018
Randall Jacobs of MEP Associates, LLC appealing IMC Section 608.3.3.2.1.
The rule requires that a smoke detector be installed within five feet of damper. There are two different situations. The Madison Fire Department supports the variance for a distance greater than five feet.
Alder District 4

Sponsors:
Indexes:
Code sections:
Attachments: 1. Martin Luther King Jr Blvd 215 application.pdf

Date	Ver.	Action By	Action	Result
7/17/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

215 Martin Luther King Jr Blvd C-07-60-2018
Randall Jacobs of MEP Associates, LLC appealing IMC Section 608.3.3.2.1.
The rule requires that a smoke detector be installed within five feet of damper. There are two different situations. The Madison Fire Department supports the variance for a distance greater than five feet.
Alder District 4