



## Legislation Details

---

**File #:** 52419      **Version:** 1      **Name:** 215 Martin Luther King Jr Blvd  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 7/11/2018      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 7/17/2018  
**Enactment date:**      **Enactment #:**  
**Title:** 215 Martin Luther King Jr Blvd C-07-60-2018  
Randall Jacobs of MEP Associates, LLC appealing IMC Section 608.3.3.2.1.  
The rule requires that a smoke detector be installed within five feet of damper. There are two different situations. The Madison Fire Department supports the variance for a distance greater than five feet.  
Alder District 4

**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. Martin Luther King Jr Blvd 215 application.pdf

Date	Ver.	Action By	Action	Result
7/17/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	